



BI-ANNUAL WELL INSPECTION CHECKLIST

Visually inspect system for leaks.

Visually inspect pressure switch for insects or burnt connections.

Visually inspect pressure gauge for proper operation.

Compare gauge pressure reading to well operating pressure.
The operating pressure should be inside pressure switch cap.

Verify well tank pressure setting. Place system in "OFF" position or shut off at the breaker. Drain the well pressure tank. Ensure air pressure in bladder tank is 2 PSI less than the cut-on pressure listed inside of pressure switch cap.

If you have any questions, please call Bowen Plumbing Supply at 352-629-7916 for assistance.